

STAIRWELL LIGHTING OPERATES NEEDLESSLY

Stairwells are lit 24 hours per day regardless of occupancy. For those with high-wattage light fixtures (T12s or T8s), 24-hour use can result in a significant and unnecessary waste of electricity.

Although occupancy sensors are widely available to switch off stairwell lighting during unoccupied periods, they require custom installations and do not provide illumination during unoccupied periods as required by code.

Bi-level stairwell fixtures with integrated occupancy sensors are easy to install and even easier to operate—they're automatic! The system is designed to provide safe, reliable, and efficient lighting with high illumination during occupied periods and reduced illumination when stairwells are vacant. However, these fixtures are just emerging on the market and both building owners and code officials have had little exposure to them.

PIER researchers installed bi-level fixtures from LaMar Lighting in four buildings, ranging from a 5-story commercial office to a 10-story university classroom/office. They monitored occupancy schedules and energy use and experienced no code issues.

The bi-level fixture has no special installation requirements and has standby wattage consumption as low as eight watts using a one-lamp 25W T8 fixture.

BI-LEVEL STAIRWELL FIXTURE RESEARCH STUDY

*WORKING WITH THE INTERNATIONAL FACILITY
MANAGEMENT ASSOCIATION (IFMA), RESEARCHERS
MONITORED BI-LEVEL FIXTURES IN FOUR CALIFORNIA
SITES, MEASURING OCCUPANCY USE PATTERNS,
ENERGY SAVINGS, AND INSTALLATION COST.
RESULTS INDICATE STANDBY OPERATION 15%–40%
OF THE TIME FOR LOWER FLOORS AND 60%–90%
FOR UPPER FLOORS, VARYING BETWEEN WEEKDAYS
AND WEEKENDS. ENERGY SAVINGS TOTALED 40%–
60%.*



Bi-level Stairwell Fixture

CUT ENERGY USE WHILE PROVIDING CONTINUOUS LIGHTING

Bi-level stairwell fixture technology provides peace of mind by offering standby lighting levels for safety and security when the space is unoccupied, and full light output when the space is occupied.

Benefits

- Standby operation meets code minimum illumination requirements
- Typical 40–60% energy savings provides 3 to 8 year simple payback depending on existing lighting and new versus retrofit applications
- Various models are available to meet most applications:
 - One- or two-lamp fixtures
 - 120V or 277V models
 - Bi-level, step-down ballasts to 5, 10, or 33 percent of full light output (i.e. two 4-ft T8s with step down to 10 percent reduces power from 62 Watts at full output to 13 Watts at standby)
- Integrated ultra-sonic motion sensor simplifies design, purchase, and installation
- 100-hour lamp conditioning circuit assures long lamp life
- Adjustable time in full output operation ranges from 15 seconds to 30 minutes
- Emergency operations options available
- Five-year factory warranty on all ballasts and sensor components.

INTERESTED?

Building owners, facility managers, contractors, design engineers, building code developers, and utility staff can leverage the bi-level stairwell lighting study results in their future efforts.

Key next steps include:

- Identify buildings with stairwells that are over-lit or using high-wattage fixtures
- Identify utility financial incentives to offset initial cost and publicize availability to lighting designers and contractors
- Publicize energy savings and cost-effectiveness results to building owners, lighting designers, and contractors
- Standardize this technology for use in new stairwells
- Inform code officials about successful applications and acceptance in numerous code jurisdictions

To purchase or learn more about the system, visit www.occusmart.com.

This project was part of the PIER Lighting Research Program. To view the project results, as well as other current research activities, visit www.energy.ca.gov/pier.

Additional information about this technology can be found on the following websites:

- PIER contractor site:
www.archenergy.com/lrp/lightingperf_standards/project_5_1_impacts.htm
- PIER researcher site:
http://lighting.lbl.gov/l_controls



Funded by the
California Energy Commission
Public Interest Energy Research Program

Contact information:

California Energy Commission
www.energy.ca.gov/pier
Michael Seaman
mseaman@energy.state.ca.us

Architectural Energy Corporation
www.archenergy.com
Judie Porter
jporter@archenergy.com

International Facility Management
Association
www.ifma.org
Shari Epstein
Shari.epstein@ifma.org

Lawrence Berkeley National Laboratory
www.lbl.gov
Francis Rubinstein
FMRubinstein@lbl.gov

Arnold Schwarzenegger, *Governor*
California Energy Commission
Chairman: Joe Desmond
Commissioners: Arthur H. Rosenfeld, James D. Boyd,
John L. Geesman, Jackalyne Pfannenstiel

BI-LEVEL STAIRWELL FIXTURES



THE RIGHT STAIRWELL
LIGHT LEVELS WHEN
YOU NEED IT



Public Interest
Energy Research