

## COMPONENT LOAD SUMMARY

Date:	October 04, 2007	Rating No.:	XYZ-22233
Building Name:		Rating Org.:	L.A. Raters
Owner's Name:	I.M. Smith	Phone No.:	303 222 1111
Property:	2342 Maybee Ave.	Rater's Name:	H.I. Scorer
Address:	Denver, CO 80333	Rater's No.:	303 333 2222
Builder's Name:	WeeBeeGood Builders		
Weather Site:	Denver, CO	Rating Type:	Based on plans
File Name:	HighEfficiency.blg	Rating Date:	4/12/07

### HighEfficiency

<b>HEATING SEASON (MMBtu/yr)</b>		← Loads for the heating season,
Ceilings/Roofs	2.6	
Rim/Band Joists	0.9	
Above Grade Walls	25.5	
Foundation Walls	0.0	
Doors	1.1	
Windows/Skylights	6.3	
Frame Floors	0.0	
Crawl Space/Unht Bsmt	5.0	
Slab Floors	0.0	
Infiltration	2.7	
Mechanical Ventilation	5.0	
Ducts	0.0	
Active Solar	-22.5	
Sunspace	-1.1	
Internal Gains	-20.2	
<b>Total</b>	<b>5.3</b>	

<b>COOLING SEASON (MMBtu/yr)</b>		← and cooling season,
Ceilings/Roofs	0.3	
Rim/Band Joists	-0.1	
Above Grade Walls	-0.6	
Foundation Walls	0.0	
Doors	-0.1	
Windows/Skylights	1.6	
Frame Floors	0.0	
Crawl Space/Unht Bsmt	-0.5	
Slab Floors	0.0	
Infiltration	-0.1	
Mechanical Ventilation	-0.3	
Ducts	0.0	
Active Solar	0.0	
Sunspace	2.2	
Internal Gains	15.6	
Whole House Ventilation	-5.7	
<b>Total</b>	<b>12.0</b>	

are displayed separately so that problem areas can be defined quickly, and accurately.

---


## COMPONENT LOAD SUMMARY

---

Date:	October 04, 2007	Rating No.:	XYZ-22233
Building Name:		Rating Org.:	L.A. Raters
Owner's Name:	I.M. Smith	Phone No.:	303 222 1111
Property:	2342 Maybee Ave.	Rater's Name:	H.I. Scorer
Address:	Denver, CO 80333	Rater's No.:	303 333 2222
Builder's Name:	WeeBeeGood Builders		
Weather Site:	Denver, CO	Rating Type:	Based on plans
File Name:	HighEfficiency.blg	Rating Date:	4/12/07

---

### Heating Season



### Cooling Season

